# CDL-608C24

## **Operation and Specification**

PIR & Ultrasonic Occupancy Sensor

CDL-608C24 embodies the technology of infrared and ultrasonic motion detection into one easy-to-install occupancy sensor. Mounted at a height of 2.4m, this sensor detects people moving within 8m diameter of a full circular coverage area.

CDL-608C24 can be surface mounted or flush mounted for an attractive, un-obstructive appearance. One or many sensors can be connected with Suren's (or compatible) power packs to control a wide range of load types, including lighting or HVAC devices.

#### <u>Operation</u>

Initialization:

The sensor becomes operational 30 seconds after power is supplied.

#### **Detection and Activation:**

When a person enters a room, the sensor detects major body motion and turns the light on. The light is kept on even as smaller body movement is detected. The sensor's **Detection Sequence Logic** (DSL) minimizes false triggering by adjusting detection sensitivity based upon sequence of occupancy events. The **Sunset Sensor** provides additional control such that lighting is not activated when there is sufficient brightness in the area.

#### **De-Activation (Normal Occupancy Mode):**

When motion is no longer detected, the sensor turns the light off after a set time delay (Delayed-Off Time).

#### Walk-thru Mode:

The walk-through feature is useful in areas that are momentarily occupied, e.g. hallway. If the sensor detects no movement for more than 10 seconds light was turned off, it will apply a Delayed-Off Time of 2.5 minutes. If the sensor detects movement less than 10 seconds after light was turned off, it will next turn the light off based upon the set time delay.

#### Installation

Accessories:

- · Brackets, screws and wall plugs for surface mount in solid ceiling
- · Spring clips for flush mount in drop ceiling
- Infrared zone mask

#### Location:

- Determine the number of sensors required to cover the floor area
- Install the sensor near work area where walk-path cuts across radial lines, not towards the sensor
- Do not install the sensor near ventilation outlet
- Avoid facing the ultrasonic transceivers to each other to minimize interference

#### Procedure:

- Prepare sensor mount. See illustration in the next page
- Connect the sensor as shown in the wiring diagram. Make sure power supply is turned off
- Make sure there are no wiring exposed before mounting the sensor
- · Mount the sensor and turn on the power supply
- Open the cover, review settings and change if necessary. See Settings section
- Initiate test mode, replace the cover and conduct walk-test

#### Walk-Test:

- Toggle dip switch B3 (Off-On-Off) to enter test mode. If B3 is already in the On position, moving it to the Off position will also activate test mode
- Amber LED will flash once every second when the sensor is in test mode
- During this time, the sensor will turn the light off after 5 seconds if there are no movement
- Test movement at entry point, walk path and occupancy area
- Sensor will exit test mode after 15 minutes

### LED Indicator:

- · LED indicator can be enabled or disabled by dip switch setting
- Recommended for troubleshooting
- Red LED indicates motion detected by infrared sensor
- Green LED indicates motion detected by ultrasonic sensor

@2011 SUREN Systems, Ltd.. All rights reserved. SUREN  $^{\rm TM}$ 







Wiring Diagram:



Power Supply: 24 V DC (Power pack PS-124 or PS-224 required)

Power Consumption: 0.96 W

Control Signal Output: 24 V DC, 15 mA

PIR Sensor: Pyroelectric, 2-element

Ultrasonic Frequency: 40 Khz Specification Housing Material: 4 High-impact ABS

> **Dimension:** 110mm Diameter x 56 mm Height

> **Operating Temperature Range:** -40° to 55° C

**RF Immunity:** 20 V/m 10-1000 Mhz; 10 V/m 1-2 GHz

Approvals: ζξ 🙆

SUREN Part no.: N-ML00-0045-01-1 Rev.3

